

Energy analyses - DWA Neighbourhood Programme

Dr. Stefanie Budewig



DWA

German Association for Water,
Wastewater and Waste

What do we do?



Technical-Scientific Association – Non Government Organisation



Background

- ▶ Waste water treatment plants often have a very **high energy use** compared to other municipal facilities.

Not enough information!

- ▶ Waste water treatment plants can **produce energy**.
- ▶ Energy is an extremely **important topic** in Germany – especially as nuclear plants are not seen as a sustainable solution.

Energy analyses

Challenges

- ▶ Lack of data for sewage treatment plants
- ▶ Lack of defined parameters
- ▶ Lack of data on a specific treatment plant
- ▶ Many influencing factors
- ▶ Specific conditions lead to a high variety
- ▶ Motivation ?

Rules and standards

A draft standard (DWA-A 216) will be published next year defining:

- ▶ Energy checks and analysis
- ▶ Relevant parameters
- ▶ Aims to be the basis of data collection to ensure comparability



Kennwerte des Energiechecks

Kläranlagen:

	Einheit	Bezeichnung		Defintion verwendeter Größen
e_{ges}	[kWh/(E·a)]	Spez. Stromverbrauch Gesamt	$e_{ges} = E_{ges} / EW_{CSB}$	E_{ges} = Stromverbrauch gesamt [kWh/a] EW_{CSB} = Einwohnerwert bezogen auf 120gCSB /EW*d [E+EGW]
e_B	[kWh/(E·a)]	Spez. Stromverbrauch Belüftung	$e_B = E_B / EW_{CSB}$	E_B = Stromverbrauch Belüftung Belebungsbecken [kWh/a] EW_{CSB} = Einwohnerwert bezogen auf 120gCSB /EW*d [E+EGW]
Kläranlagen mit Faulung				
$e_{FG,1}$	[I_N /(E·d)]	Spez. Faulgasproduktion	$e_{FG} = Q_{FG} / EW_{CSB}$	Q_{FG} = Jahresmittelwert der Faulgasproduktion [I_N /d] (normiert auf 0°C und 1013 mbar) EW_{CSB} = Einwohnerwert bezogen auf 120gCSB /EW*d [E+EGW] $m_{oTS,ZU}$ = Jahresmittelwert zugeführte oTR-Fracht zur Faulung [kg oTR _{ZU}]
$e_{FG,2}$	[I_N /kgoTS]		$e_{FG} = Q_{FG} / m_{oTS,ZU}$	
N_{FG}	[%]	Grad der Faulgasumwandlung in Elektrizität	$N = (E_{KWK}/E_{FG}) \cdot 100$	E_{KWK} = Jahresproduktion KWK Anlagen bzw. Direktantrieb von Verdichtern [kWh/a] E_{FG} = Heizwert der Jahresfaulgasproduktion = $Q_{FG} \cdot HI_{,n 1}$ ($HI_{,n 1}$ = Heizwert Faulgas = 6,4 kWh/m ³)
V_E	[%]	Eigenversorgungsgrad Elektrizität	$V_E = (E_{KWK}/E_{ges}) \cdot 100$	E_{KWK} = Jahresproduktion Strom aus KWK Anlagen bzw. Direktantrieb von Verdichtern [kWh/a] E_{ges} = Stromverbrauch gesamt [kWh/a]
e_{ext}	[kWh/(E·a)]	Spez. externer Wärmebezug	$e_{ext} = E_{therm} / EW_{CSB}$	E_{therm} = extern zugeführte Wärmemenge [kWh/a] = $Q_{Primärenergieträger} \cdot HI_{,n1}$ $HI_{,n1}$ = Heizwert Heizöl = 10 kWh/l $HI_{,n1}$ = Heizwert Erdgas = 9,4 kWh/m ³

Pumpwerke:

Spez. Stromverbrauch pro m³ und manometrischer Förderhöhe [Wh/m³*m]

Benchmarking




Profile of the
German Water Sector
2011
Summary



- ▶ Report for the public
- ▶ Highly aggregated level of benchmarking data
- ▶ Long and short version covering relevant aspects of the water sector

Neighborhoods – help each other



- ▶ Sewage-neighborhoods since 1968
- ▶ Goal continuous training of operating personnel
- ▶ By now about 500 neighborhoods (sewage treatment plants, sewer, and water) exist
- ▶ Each year, about 20,000 participants train in various areas

Neighborhoods – comparison of performance



Leistungsvergleich kommunaler Kläranlagen 2011

This year

„Use of electricity“

Data from 4 300 treatment plants was compared.



Kläranlage Stuttgart-Mühlhausen



Kläranlage Böttingen-Sindelfingen




Kläranlage Freudenstadt-Manbach



Kläranlage Forchheim


Stromverbrauch:
4.300 Kläranlagen unter
der Lupe



Neighborhoods – comparison of performance



- ▶ Annual comparison of performance since 1988
- ▶ Nearly 6 000 wastewater treatment participate



Neighborhoods – comparison of performance



Leistungsvergleich kommunaler Kläranlagen 2011

„Use of electricity“

Results?



Kläranlage Stuttgart-Mühlhausen



Kläranlage Böttingen-Sindelfingen




Kläranlage Freudenstadt-Manbach




Kläranlage Forchheim

Stromverbrauch:
4.300 Kläranlagen unter
der Lupe



Results



Amount of electricity used in sewage treatment plants of different sizes.

Results



	Anzahl	Ausbau- größe	Mittlere Belastung	Stromver- brauch	spez. Stromver- brauch
Dimension	–	Mio. EW	Mio. EW	GWh/a	kWh/ (EW*a)
GK 1	811	0,4	0,4	22,7	54,1
GK 2	1.292	3,6	3,1	128,6	41,5
GK 3	610	4,7	4,0	152,6	38,1
GK 4	1.415	46,1	36,0	1.229,3	34,1
GK 5	203	66,0	51,2	1.684,6	32,9
Gesamt	4.331	120,8	94,7	3.217,7	34,0

Tabelle 2: Jährlicher Stromverbrauch der Kläranlagen

Summary



- ▶ Detailed analysis or benchmarking are not easily possible as the criteria are not clearly defined
- ▶ In many cases energy consumption is not measured for the individual processes
- ▶ Data collection presents additional work



Summary



Leistungsvergleich kommunaler Kläranlagen 2011



Stromverbrauch:
4.300 Kläranlagen unter
der Lupe



- ▶ Energy is an important topic in Germany
- ▶ Defined parameters will be available shortly
- ▶ Structures for voluntary data collection exist

Conclusions

The way forward:

- ▶ Defined comparable parameters
- ▶ Voluntary data collection to evaluate appropriateness
- ▶ Spreading discussion and information exchange on all levels

The goal:

Optimising energy use and production!




Following the discussion



One step after the next:

- ▶ Define specific areas
- ▶ Look at what you want to know
- ▶ Look a why you want to know it
- ▶ Find suitable parameters
- ▶ Find a motivation
- ▶ Go slowly, build trust



Energy

Use in specific processes

Optimise energy use

DWA Standard 216

Expert support in analysis

Communication, exchange
of experience, influence on
reporting ...

Thank you for your attention!



Dr. Stefanie Budewig

DWA

German Association for Water, Wastewater and Waste

budewig@dwa.de

www.dwa.de