

**European Water Utility Expert meeting at EEA 2012**

# **Target setting for energy efficiency from global and European to utility level**

**Jacques Labre – Suez Environnement**

**[jacques.labre@suez-env.com](mailto:jacques.labre@suez-env.com)**

# Outline

- **Target setting for a global action plan on energy efficiency (World Water Forum / IWA)**
- **Benchmarking on energy efficiency in Suez Environnement's water operations**



# Global action plan for energy efficiency : on going process

## **6<sup>th</sup> World Water Forum : The Forum of Solutions” (march 2012)**

Thematic component structured around 12 Priorities for Action

Priority 2.3 : “Harmonize Energy and Water”, including 8 targets, notably :

Target 1 : Improve energy efficiency of water and waste water services  
(target leader: IWA)

Target 2 : Implement Best Available Technologies in Desalination  
(target leader: IDA)

Target 3 : Link access to water and access to energy for poor isolated communities (target leader: Electriciens Sans Frontières)

...

Target 8 : Establish a network of water and energy policy makers  
(target leader : Norwegian ministry of Petroleum and Energy)

Progress on each target will be monitored by the World Water Council, and reported at the 7<sup>th</sup> World Water Forum (Korea 2015)



# Target set up for water utilities at the 6<sup>th</sup> World Water Forum : consistent with the EU energy efficiency overall target

**Target** 2.3.1: *Measures are implemented by public authorities and water utilities in cities totalling 500 million inhabitants, aiming at a minimal improvement of 20% of energy efficiency of municipal water and wastewater systems by 2020 compared to 1990 level*

**Coordinator :** International Water Association (IWA)

**Members of the Target and Solutions Group :** European Environmental Agency, ICLEI , World Bank , DANVA , Water Supply and Sanitation Technological Platform, Lund University, Suez Environnement

**Link to Target documents**

[http://www.worldwaterforum6.org/en/library/detail/?tx\\_amswwfbd\\_pi2\[uid\]=642](http://www.worldwaterforum6.org/en/library/detail/?tx_amswwfbd_pi2[uid]=642)


**Link to Solutions** <http://www.solutionsforwater.org/objectifs/2-3-1-energy-efficiency-of-urban-water-systems>



# Follow up : within IWA's programme "Water Climate and Energy"

The WCE programme includes 4 components:


- Urban water-energy information and frameworks
- Demonstration of urban water-energy neutrality in utilities and cities
- Technologies to achieve urban water-energy neutrality
- Policy and communication to promote water-energy neutrality



# What indicators for progress monitoring at city (system) level ?

## Prerequisites for the choice of a indicators (1)

- All the terms of energy consumption are site specific ; they depend :
    - either of geographic conditions (relief , distance to water source , population density )
    - or of (local) environmental constraints that determine the level of waste water treatment
  - Therefore **horizontal** benchmarking (comparison between sites ) is not very relevant
- **The major objective should be vertical benchmarking (measurement of progress over time)**


$$I = \frac{\text{current\_performance}}{\text{baseline\_performance}}$$

# What indicators for progress monitoring at city (system) level ?

## Prerequisites for the choice of indicators (2)

- The performance should refer to **net energy consumption** (energy in less energy out) → « Energy out » means energy generated **from the process** and used for useful purpose (be it thermal or electric )
  - *E.g. power produced by a windmill installed on the site of a treatment plant is not generated from the process*
- The indicator should reflect intrinsic efficiency and not be influenced by variations in population coverage , or expansion of the systems
  - ➔ Use of ratios between energy consumption and physical units (m<sup>3</sup> ...)
- Some public authorities or operators do not cover the full urban water cycle
  - ➔ The indicator must be **disaggregated into four terms** :
    1. Efficiency in water production
    2. Efficiency in water distribution
    3. Efficiency in waste water collection
    4. Efficiency in waste water / sludge treatment

# Proposal of aggregated progress indicator (to be discussed)

- $$I = \left( \alpha \frac{W_{\text{prod}}(t)}{W_{\text{prod}}(t_0)} + \beta \frac{W_{\text{dist}}(t)}{W_{\text{dist}}(t_0)} + \gamma \frac{W_{\text{coll}}(t)}{W_{\text{coll}}(t_0)} + \delta \frac{W_{\text{treat}}(t)}{W_{\text{treat}}(t_0)} \right) \times 100$$

with  $I$  = energy efficiency progress indicator (100 for baseline year)

$\alpha \beta \gamma \delta$  : weighting coefficients representing the weight of the 4 terms for the baseline year (  $\alpha + \beta + \gamma + \delta = 1$  )

$W(t)$  = net energy consumption of the process for the current year in kWh/m<sup>3</sup> (or kWh/kg of BOD for waste water treatment)

$W(t_0)$  = net energy consumption of the process for the baseline year in kWh/m<sup>3</sup> (or kWh/kg of BOD for waste water treatment)

→ **weighted average of the progress on kWh/unit for each of the 4 activities (present value / initial situation)**



# Consolidated indicator for a set of heterogeneous systems (to be discussed)


- Proportion of sites where the indicator I is improved by more than 20% (?) since the baseline year

# Outline

- Target setting for a global action plan on energy efficiency (World Water Forum / IWA)
- **Benchmarking on energy efficiency in Suez Environnement's water operations**



# SUEZ ENVIRONNEMENT : A GLOBAL PLAYER (2010 FIGURES)



– **91 million** people supplied in drinking water

– **61 million** people served in wastewater collection & treatment



# Suez Environnement's internal benchmarking process

- **Suez Environnement is applying a common reporting framework on Environment and Performance for its 160 largest water contracts worldwide**
- **A tool serving multiple purposes:**
  - Economic performance management
  - Consolidation of data for corporate reporting
  - Internal benchmarking, identification and correction of anomalies
  - Progress monitoring
- **9 Key Performance Ratios on energy**


(+ 1 Environmental indicator on CO<sub>2</sub> emissions avoided through energy recovery):

	<b>Energy cost/total costs</b>	<b>Energy consumed/unit 1</b>	
<b>Water production</b>	%	kWh/m <sup>3</sup>	
<b>Water distribution</b>	%	kWh/m <sup>3</sup>	
<b>Sewage collection</b>	%	kWh/m <sup>3</sup>	
<b>Sewage treatment</b>	%	kWh/kg BOD removed	kWh/kg BOD+N removed



# How the results look like

Graph D56 - SEWAGE TREATMENT  
Electricity consumed / BOD removed (KWh/Kg BOD)



Electricity consumption varies widely from one site to another. Lowest and highest values may require a review. This includes electricity consumption for both BOD and nitrogen treatments indistinctly. Since 2009 the average tends to slightly decrease from 2,4 down to 2,1 kwh/kg BOD on average. There is a general downward tendency.

A theoretical approach enables us to isolate the energy fraction associated to nitrogen removal treatments, as presented in graph D62.

Good

Ratio value  
From 1 up to 3

# Average figures for Suez Environnement worldwide (for year 2010)

- **Scope (population sample / total population served worldwide) :**
  - Drinking water : 67 million / 91 million
  - Waste water : 39 million / 61 million
- Average energy consumption :
  - Drinking water production : 0.39 kWhe/m<sup>3</sup>
  - Drinking water distribution : 0.11 kWhe/m<sup>3</sup>
  - Waste water collection : 0.07 kWhe/m<sup>3</sup>

} site specific

  - Waste water treatment : 2.38 kWhe/kg BOD removed  
(including 20% of extra consumption for nitrogen removal where relevant)

process specific
- Average energy generation from waste water :  
66 000 t CO<sub>2</sub> equivalent



# Average figures for Suez Environnement in the EU (for year 2010)

- **Scope (population sample / total population served in the EU) :**

- Drinking water : 22 million / 32 million
- Waste water : 18 million / 26 million

- Average energy consumption :

- Drinking water production : 0.52 kWhe/m<sup>3</sup>
  - Drinking water distribution : 0.12 kWhe/m<sup>3</sup>
  - Waste water collection : 0.07 kWhe/m<sup>3</sup>
- } site specific

- Waste water treatment : 2.2 kWhe/kg BOD removed  
(including 20% of extra consumption for nitrogen removal where relevant)
- process specific



**Thank you for your attention !**

